



**Providing safe, reliable, affordable, and sustainable service.**

**Prairie Ridge 605  
ODW ID# 02356W  
Part B Water System Plan**

**Prepared By  
Doug Piehl, P.E.  
January 14, 2026**



1230 Ruddell Rd. SE  
Lacey, WA 98503  
(866) 357-8783  
Fax (360) 357-1172  
[www.thurstonpud.org](http://www.thurstonpud.org)

---

# Part B Water System Plan Update

## For The

### Prairie Ridge – 605 Water System

### WSID: 02356W

#### EXECUTIVE SUMMARY:

Thurston PUD is submitting a Water System Plan (WSP) Update to accomplish the consolidation of three water systems into a single system to be known as the Prairie Ridge 605 Water System (DOH ID 02356W):

- Prairie Ridge 605 (DOH ID 02356W)
- Hawk Acres 607 (DOH ID 31845T)
- Tolmie Park 239 (DOH ID 88667P)

The submitted document is the Part B Water System Plan; please refer to the Thurston PUD Part A (Umbrella) Plan for PUD standards, policies, asset management, and rate setting. Thurston PUD requests approval of the WSP for a 10-year planning period, along with approval to use the distribution submittal exemption per submittal documents and approval of the Part A Water System Plan, and an emergency intertie with the Lacey Water Department.

The service area of the consolidated system is the same as that of the existing service areas of the constituent water systems, with the exception of an addition of four parcels on the east of the existing Prairie Ridge service area, which were previously not serviced. Currently 303 connections are served by the consolidated system, all of which are full-time single-family residences. This WSP includes a full capacity analysis of the system and proposes approval of a total of 525 connections.

|                     |   |
|---------------------|---|
| Current Population: | 778   |
| Sources:            | 5 permanent wells:<br>Pumping to storage: 2 wells, combined capacity 137 gpm<br>Pumping direct to distribution: 3 wells, combined capacity 203 gpm                          |
| Storage:            | 76,300 gallons  |
| Pressurization:     | One 3 hp booster pump, three 5 hp booster pumps<br>Three wells pumping direct to distribution; combined distribution output 596 gpm.  |
| Treatment           | Secondary Disinfection using Sodium Hypochlorite.   |
| Distribution        | 28,580 lineal feet total, of variable age and pipe material, primarily PVC installed in 1980's. Includes 13,350 feet of 6-inch, and the remainder in various smaller sizes. |
| Water Rights        | G2-25286C: 80 gpm, 30.5 acre-feet per year<br>G2-25478C: 125 gpm, 99.5 acre-feet per year<br>G2-25621C: 50 gpm, 80.0 acre-feet per year                                     |

|                        |  |
|------------------------|--|
|                        | G2-29250P: 125 gpm, 80.0 acre-feet per year (annual quantity non-additive to G2-25621)<br>G2-27015P: 175 gpm, 50.0 acre-feet per year (125 gpm additive to G2-25621, 50 gpm and 50.0 acre-ft/yr non-additive to G2-25621)  |
| ADD/ERU                | 180 gpd  |
| MDD/ERU                | 672 gpd  |
| Current PHD            | 335 gpm  |
| 20 Yr PHD              | 433 gpm  |
| Fire Flow Requirements | N/A – Fire flow is not required for the existing platted areas. Further subdivision or commercial/high density development may require fire flow, to be addressed by developer improvement as necessary. New single family home connections to the water system may require installation of residential fire suppression system as directed by the Thurston County Fire Marshal. |

## TABLE OF CONTENTS

|           |  |    |
|-----------|--|----|
| Chapter 1 | System Description .....   | 1  |
| 1.1       | Ownership and Management .....   | 1  |
| 1.2       | System Background.....   | 1  |
| 1.3       | Related Plans.....   | 5  |
| 1.4       | Service Area, Maps, and Land Use .....   | 5  |
| 1.5       | System Policies.....   | 12 |
| 1.6       | Duty to Serve.....   | 14 |
| 1.7       | Local Government Consistency.....  | 14 |
| 1.8       | Watershed Plan Consistency.....  | 14 |
| Chapter 2 | Basic Planning Data .....  | 15 |
| 2.1       | Current Population, Service Connections, and Equivalent Residential Units (ERUs) ..... | 15 |
| 2.2       | Water Production and Usage.....  | 15 |
| 2.3       | Distribution System Leakage.....   | 18 |
| 2.4       | Water Supply Characteristics .....   | 19 |
| 2.5       | Water Supply Reliability Evaluation .....  | 19 |
| 2.6       | Future Population Projections and Land Use .....                                       | 19 |
| 2.7       | Future Water Demand .....  | 20 |
| Chapter 3 | System Inventory and Analysis .....  | 22 |
| 3.1       | System Design Standards.....   | 22 |
| 3.2       | System Inventory and Asset Condition Assessment .....                                  | 22 |
| 3.3       | Capacity Analysis.....   | 25 |
| 3.4       | Distribution System Analysis.....  | 30 |
| 3.5       | Summary of System Deficiencies .....   | 31 |
| Chapter 4 | Water Use Efficiency Program .....   | 32 |
| 4.1       | Source and Service Metering .....  | 32 |
| 4.2       | Distribution System Leakage.....   | 32 |
| 4.3       | Water Use Efficiency Program .....   | 33 |
| 4.4       | Demand Forecast .....  | 34 |
| 4.5       | Water Use Efficiency Savings .....   | 34 |
| 4.6       | DSL Exemption for Water Systems under 500 Connections.....                             | 35 |
| Chapter 5 | Source Water Protection .....  | 36 |
| 5.1       | Wellhead Protection .....  | 36 |
| 5.2       | Water Quality Analysis.....  | 38 |
| Chapter 6 | Operations and Maintenance .....   | 39 |
| 6.1       | Water System Management, Personnel, and Certifications.....                            | 39 |
| 6.2       | Operations and Preventative Maintenance.....   | 39 |
| 6.3       | Comprehensive Water Quality Monitoring .....   | 39 |
| 6.4       | Emergency Response Program .....   | 40 |
| 6.5       | Cross Connection Control .....   | 40 |

|            |   |    |
|------------|---|----|
| 6.6        | Sanitary Survey Findings .....                                    | 40 |
| 6.7        | Summary of O&M Deficiencies .....                                 | 40 |
| 6.8        | Record Keeping, Reporting, and Customer Complaint Program .....   | 40 |
| 6.9        | Customer Complaint Response Procedures .....                      | 41 |
| Chapter 7  | Distribution Facilities Design and Construction Standards.....    | 42 |
| Chapter 8  | Capital Improvement Program .....                                 | 43 |
| 8.1        | Prioritization Criteria.....                                      | 43 |
| 8.2        | Prioritized List of Improvements.....                             | 43 |
| 8.3        | Assessment of Improvements.....                                   | 43 |
| 8.4        | Improvement Program Summary and Schedule.....                     | 45 |
| Chapter 9  | Financial Program .....   | 46 |
| Chapter 10 | Appendices and Supporting Documents.....                          | 47 |
| 10.1       | Hydraulic Analysis .....  | 47 |
| 10.2       | Well Logs, Pump Curves, and Equipment .....                       | 47 |
| 10.3       | Meter Data .....  | 47 |
| 10.4       | WFI and Operating Permit .....                                    | 47 |
| 10.5       | Water Rights .....  | 47 |
| 10.6       | Wellhead Contamination Susceptibility Assessments .....           | 47 |
| 10.7       | Water Quality Monitoring Programs, Cross Connection Control ..... | 47 |
| 10.8       | Consistency Statements, WSP Adoption, and Correspondence .....    | 47 |
| 10.9       | Easements, Covenants, Legal Instruments .....                     | 47 |
| 10.10      | Maps and Drawings.....  | 47 |

## LIST OF TABLES

|   |    |
|---|----|
| Table 2-1: Summary of Current Systems Design Parameters ..... | 17 |
| Table 2-2: Population and Water Use Projections .....         | 21 |
| Table 3-1: Pipe Inventory .....                               | 22 |
| Table 3-2: Valve, Blow-off, and Appurtenance Inventory .....  | 23 |
| Table 3-3: Summary of Sources .....                           | 23 |
| Table 3-4: Summary of Submersible Well Pumps .....            | 24 |
| Table 3-5: Summary of Submersible Well Pumps .....            | 24 |
| Table 3-6: Summary of Booster Pumps .....                     | 25 |
| Table 3-7: Summary of Buildings .....                         | 25 |
| Table 3-8: Limiting Factor Capacity Summary .....             | 25 |
| Table 6-1: Normal Operating Conditions .....                  | 39 |
| Table 8-1: Improvement Schedule .....                         | 45 |

## LIST OF FIGURES

|  |    |
|--|----|
| Figure 1-1: NRCS Soil Map.....   | 3  |
| Figure 1-2: Map of Critical Aquifer Recharge Areas.....                            | 4  |
| Figure 1-3: Prairie Ridge Water System Section Map.....                            | 6  |
| Figure 1-4: Prairie Ridge Water System vicinity map.....                           | 7  |
| Figure 1-5: Service Area Expansion.....  | 8  |
| Figure 1-6: Service Area, Retail Service area, and Water Rights Place of Use ..... | 9  |
| Figure 1-7: Area Zoning Map .....  | 11 |
| Figure 1-8: Aerial Photographs .....   | 12 |
| Figure 2-1: Monthly Average Consumption per ERU .....                              | 16 |
| Figure 2-2: DSL Rate .....   | 18 |
| Figure 2-3: Annual Average DSL Percent .....                                       | 18 |
| Figure 4-1: Annual Average DSL Percent .....                                       | 35 |
| Figure 5-1: Wellhead Protection Areas.....   | 37 |

# Prairie Ridge 605

---

## *Water System Plan*

### **Acronyms**

|       |  |
|-------|--|
| ADD   | Average Daily Demand                             |
| C     | Coefficient of Friction                          |
| DSL   | Distribution System Leakage                      |
| ERU   | Equivalent Residential Unit                      |
| GWI   | Groundwater Under the Influence of Surface Water |
| HGL   | Hydraulic Grade Line                             |
| MCL   | Maximum Contaminant Level                        |
| MDD   | Maximum Daily Demand                             |
| MPA   | Microscopic Particulate Analysis                 |
| NTNC  | Non-Transient Non-Community                      |
| PHD   | Peak Hourly Demand                               |
| ppb   | Parts per Billion                                |
| ppm   | Parts per Million                                |
| RSA   | Retail Service Area                              |
| SMA   | Satellite Management Agency                      |
| SWL   | Static Water Level                               |
| SWSMP | Small Water System Management Program            |
| UTC   | Utilities and Transportation Commission          |
| WDM   | Water Distribution Manager                       |
| WFI   | Water Facilities Inventory (form)                |
| WSDM  | Water System Design Manual                       |
| WSDOH | Washington State Department of Health            |
| WSP   | Water System Plan                                |
| WUE   | Water Use Efficiency                             |

# Chapter 1 System Description

## 1.1 Ownership and Management

The Prairie Ridge 605 water system is a consolidation of three existing systems, (Prairie Ridge 605, Hawk Acres 607, and Tolmie Park 239). The water system is owned and operated by Thurston PUD, a Public Utility District established by the vote of the people in 1938. Thurston PUD owns and manages multiple water systems and has approved umbrella Part A (Part A) and Satellite Management Agency (SMA) plans that cover information that is relevant to the management of multiple systems. These documents are referenced where applicable. See Thurston PUD's Part A for information on the Ownership and Management structure.

Pertinent information about the water system is summarized below:

|                      |  |
|----------------------|--|
| Water System Name:   | Prairie Ridge 605                              |
| System Type:         | Group A Community Water System                 |
| WSDOH ID Number:     | 02356  |
| Location:            | Thurston County, Washington                    |
| Source:              | Groundwater                                    |
| Type of Ownership:   | Special Purpose District                       |
| Service Connections: | 303  |
| Population Served:   | 778  |
| Ownership            | Thurston PUD (owner/operator)                  |
| Primary Contact:     | Kim Gubbe, Director of Planning and Compliance |
| Owner Address:       | 1230 Ruddell Rd SE<br>Lacey WA 98503           |
| Owner Phone:         | (360) 357-8783                                 |

## 1.2 System Background

### 1.2.1 History

The prior history of the three Group A water systems which are now consolidated and hereafter known as the Prairie Ridge water system are described below.

The Tolmie Park Estates Water System was originally approved to serve 47 single-family homes in 1979. The system was subsequently approved for 67 connections in May, 1996. The original owner was Wally Pratt who developed the water system along with the 47-lot subdivision of Tolmie Park Estates. Mr. Pratt sold the water system to Clearwater Utilities, who in turn sold it to Satellite Water Systems. American Water Resources purchased the water system from Satellite Water Systems in May 1996, and it was incorporated into Thurston PUD in April 2005.

The Hawk Acres Water System began service in 1963 with the drilling of well 1 and with an initial 2 connections. In 1969 the system expanded to 87 connections, and was approved for 116 connections in 1973. A second well was installed in 2005 in order to increase system capacity and allow additional services. The system was owned by John D Swift / Swift Asset Management Company, Inc. under the

Marvin Road Water Company (MRWC) from inception until May 2014, when the system was incorporated into Thurston PUD.

The Prairie Ridge water system was created in 1980 Robert Drophman to serve the Prairie Ridge subdivision, consisting of four divisions. The first division was platted in April 1981 (volume 21 of Plats, page 123), and was served with Well 1. Division 2 was platted in 1984 (volume 22 of Plats, page 56), at which time the water system added a small steel reservoir, Reservoir 1, and booster pumps at the wellsite. Division 3 was platted in 1992 (volume 25 of Plats, page 92), and included construction of an additional reinforced concrete reservoir, Reservoir 2 at the well site to augment the storage capacity of Reservoir 1. In 1996, a second well was drilled to increase supply and provide source redundancy. Division 4 was platted in 2000 (AFN 3309071) and included construction of a second concrete reservoir (reservoir 3) along with an additional booster pump and disconnection (and later removal) of the old steel reservoir (reservoir 1). The water system was owned and operated by Robert Drophman under the Prairie Ridge Water Company until Thurston Public Utility District assumed ownership and operation of the system in June 2010. The system currently serves 102 single family residential connections and is approved to serve 123 single family residential connections. The zoning is now "Rural Residential-Resource 1 unit per 5 acres. There are parcels in the service area which are owned by the North Thurston School District and may be developed as public schools.

### **1.2.2 Geography**

The Prairie Ridge Water System service area is located in Hawks Prairie, a peninsular upland area in Northern Thurston County. Average annual rainfall in the service area is 49 inches. The highest area in the service area is at an approximate elevation 300 feet above MSL in the SW corner of the School District's parcel (TPN 11934100000). The highest elevation of existing water service is 294 feet, located near the intersection of 44th Avenue NE and Prairie Ridge Drive. The lowest elevation in the service area is at the southern most area of the service area on 32<sup>nd</sup> Ct NE, at 198 feet above MSL. Ground surface slopes in the service area are gently rolling, with a general loss in elevation from North to South. The service area comprises two pressure zones, the upper pressure zone (415-ft), serving the area north of Hawks Prairie Rd., and the lower pressure zone (370-ft), serving the area south of Hawks Prairie Rd. Services in the upper zone located at or below 240-ft elevation require individual pressure reducing valves.

The onsite soil is predominantly classified as Alderwood Gravelly Sandy Loam by the SCS Soil Survey for Thurston County. Alderwood soils generally include a weakly cemented hardpan about 30 inches below ground surface. A copy of the SCS Soil Description is included in Appendix 1. The annual rainfall for the Olympia WSO AP Station is 51.4 Inches. The site is located in the Henderson Watershed Protection area and includes category 1, 2, and 3 Critical Aquifer Recharge Areas as mapped by Thurston County. As a general rule, the area is not subject to high water table or flooding, with no areas of concern mapped by Thurston County near the existing groundwater wells.




Figure 1-1: NRCS Soil Map




Figure 1-2: Map of Critical Aquifer Recharge Areas

### **1.2.3 Existing Facilities**

The water system consists of two pressure zones and operates facilities at three separate sites, Tax Parcel Number (TPN) 80120100000, 11934430100, and 69330007101. The system is supplied by five permanent wells (S01, S02, S04, S05, S06). Three wells (S04, S05, S06) pump direct to distribution using variable speed drives to control output. Two wells (S01, S02) pump to two concrete reservoirs (combined volume of 76,300 gallons), with distribution via four booster pumps equipped with variable speed drives. The system is chlorinated and maintains a minimum 0.2 mg/L residual; no other water treatment is required. The well, reservoir, and booster/treatment building are all located on easement on the HOA owned tax parcel 0418321095. Distribution System consists of 28,000 lineal feet of primarily PVC pipe in a variety of pipe sizes; the most common sizes are 6-inch (13,350 feet), 4-inch (5,660 feet), and 2.5-inch (6,560 feet). The majority of existing pipe was installed around 1980, with smaller amounts of older and of recently installed pipe. Additional information can be found in Thurston PUD's Capital Asset Management Plan.

## **1.3 Related Plans**

The following documents were consulted in the preparation of this Water System Plan:

- *Thurston PUD Water System Plan: Part A - Umbrella Plan, updated November 2023*
- *Thurston PUD Satellite Management Agency Plan, March 2021*
- *Thurston County Comprehensive Plan, updated November 2019*
- *City of Lacey Comprehensive Plan, 2016*
- *Deschutes Watershed Plan (WRIA 13), December 2024*
- *Sanitary Code for Thurston County; Article III, Public Water Supplies, January 2014*
- *North Thurston County Coordinated Water System Plan—Areawide Supplement, 1996*

Adjacent Group A public water systems are the City of Lacey water system to the south and east, and Hawley Hills and Forest Park to the North. To the west is unserved area. Nearby Group B water systems include the Mayse water system to the southwest.

## **1.4 Service Area, Maps, and Land Use**

The Prairie Ridge Water System service area is located west of a county arterial, Marvin Road. It is bounded on the north by the Hawley Hills, a single-family residential subdivision and on the west by an equestrian area with barns and open fields. On the south the service area is bound by the City of Lacey. The service area comprises a significant portion of Section 34, Township 19 North, Range 1 West, as well as a portion of the NE ¼ of Section 03, Township 18 North, Range 1 West, W.M. See Figure 1-3 through Figure 1-6.

### **1.4.1 Retail Service Area**

The retail service area is where a municipal water supplier has a duty to serve connections under the conditions described in Section 1.6. For the Prairie Ridge 605 Water System, the retail service area is as shown in Figure 1-6.

#### 1.4.2 Service Area Agreements

There are no service area agreements with outside utilities. Thurston PUD and the City of Lacey have recently formalized an emergency intertie agreement, see appendix 10.9.




Figure 1-3: Prairie Ridge Water System Section Map.




Figure 1-4: Prairie Ridge Water System vicinity map.

PRAIRIE RIDGE 605 WATER SYSTEM  
SERVICE AREA EXPANSION MAP




Figure 1-5: Service Area Expansion

PRAIRIE RIDGE 605 WATER SYSTEM  
SERVICE AREA AND WATER RIGHTS PLACE OF USE





Figure 1-6: Service Area, Retail Service area, and Water Rights Place of Use

#### **1.4.3 Land Use and Zoning**

The Prairie Ridge Water System service area comprises approximately 560 acres, the majority of which has been subdivided and developed as single-family residences, with most lots generally ranging from  $\frac{1}{4}$  acre to 1 acre, along with several dozen larger parcels. There are approximately 120 acres of undeveloped land within the service area, 70 acres of which are owned by Thurston County School District 3. An additional 230 acres consists of large lots which are currently developed as single-family homes and estates, but which may be rezoned and/or redeveloped in the future.

The area of the Prairie Ridge water system lying north of 38<sup>th</sup> Way NE is under the jurisdiction of Thurston County, with the exception of parcel 11934100000, which is in the City of Lacey Urban Growth Area (UGA) and zoned OSI-S (open space intended for future school). Existing zoning outside the UGA consists of RRR1/5 (rural residential, one residence per 5 acres), RL1/1 (residential farm, one residence per acre). The area of the water system lying south of 38<sup>th</sup> Way NE is in the City of Lacey UGA, with existing zoning consisting of LD (Low density residential, 6 units per acre), and MD (moderate density residential, 8 – 16 units per acre).

Accessory Dwelling Units (ADU's) are permitted and do not count towards calculated maximum housing density. In the 20-year time horizon it is likely that there will be construction and subdivision of available vacant parcels, and likely some redevelopment and addition of ADU's to larger lots.



**Figure 1-7: Area Zoning Map**




Figure 1-8: Aerial Photographs

## 1.5 System Policies

Thurston PUD, in its commitment to provide dependable water service in accordance with all applicable regulatory rules and regulations, observes the following general policies.

### **1.5.1 Direct Connection and Satellite/Remote Systems**

Future direct connections to the Prairie Ridge water system will occur as a result of infill within the retail service area.

Satellite systems are noncontiguous or separate water systems that use separate facilities and infrastructure and may be served by a different source. See SMA plan Section 4 and Part A plan Section 2.3 for policies regarding satellite / remote systems.

### **1.5.2 Design and Performance Standards**

All design and construction shall be completed under the direction of Thurston PUD per the standards of Thurston PUD and Thurston County. Design and construction specifications and standards can be found in Thurston PUD's Part A plan, Appendix A, Specifications and Standards for Design and Construction.

### **1.5.3 Urban Growth Area**

Approximately 150 acres of the service area lies within the City of Lacey Urban Growth Area (UGA). Water service within the UGA and infill of existing platted lots is prioritized over new plats, redevelopment, and accessory dwelling units outside of the UGA. Thurston PUD pursues engagement with City of Lacey and Thurston County planning staff to facilitate water service availability to support proposed zoning changes and proposed development within the UGA.

### **1.5.4 Late-Comer Agreements**

Late-comer agreements may be considered by Thurston PUD on a case-by-case basis upon request prior to approval of developer extensions.

### **1.5.5 Oversizing**

Please see Part A plan, Appendix A Section 3 for policies regarding oversizing.

### **1.5.6 Accessory Dwelling Units**

Accessory Dwelling Units (ADUs) require a separate water service and are typically considered equivalent to 0.5 ERU. Connections for ADU's may be approved by Thurston PUD, subject to availability of connections and District discretion. See ADU policy, section 2.3.8 of Thurston PUD's Policies and Procedures Manual, Appendix A of the Thurston PUD Part A Water System Plan.

### **1.5.7 Cross-Connection Control Program (CCCP)**

Please see Part A plan Section 5.8 and Appendix R for Cross-Connection Control Program. A list of Cross-Connection Control devices and inspection dates can be found in Appendix 10.8 of this Part B water system plan.

### **1.5.8 Interties**

An emergency intertie is planned with the Lacey Water Department. The intertie agreement requires prior notification by both parties prior to opening. Both systems are chlorinated.

### **1.5.9 Extension**

In order to facilitate ongoing level of service and redundancy, extension of a 6-inch C-900 PVC main in the unopened portion of the right of way for 38<sup>th</sup> Way NE / NE Stillwell Rd between Legacy Drive NE and Hepburn St NE is planned. No further extensions are planned at this time, however minor future developer

extensions are anticipated. An extension submittal exemption is requested per WAC 246-290-125; all extension design and installation shall be completed per the Design and Construction Specifications and Standards, found in the Part A plan, Appendix A.

## **1.6 Duty to Serve**

See Part A Plan Section 2.3 for policies related to Duty to Serve.

## **1.7 Local Government Consistency**

In accordance with the Municipal Water Law, Thurston PUD is working on obtaining a signed consistency statement from Thurston County and the City of Lacey to document that this WSP is consistent with local area planning. A copy of local government consistency statements will be included in Section 10.8 of the WSP.

## **1.8 Watershed Plan Consistency**

As discussed in Section 1.3, Prairie Ridge 605 Water System is within the Deschutes watershed (WRIA 13). No inconsonances have been identified with the Deschutes Watershed Management Plan.

## **Chapter 2 Basic Planning Data**

### **2.1 Current Population, Service Connections, and Equivalent Residential Units (ERUs)**

#### **2.1.1 Population and Demographics**

The Prairie Ridge 605 water system serves 303 full time residential connections. There are no Part-time Residential, Commercial, Industrial, Agricultural or Multi-Family service connections on the water system at this time. Population is estimated at 778 persons, which is nominally higher than the statewide average of 2.5 persons per household.

Per the 2019 Thurston County Comprehensive Plan, a county wide growth rate of 42% is projected over the period of 2017 to 2040 (an average compound annual growth rate of 1.54%). Projected growth rate for the same period is 66% for the Lacy UGA, and 20% for unincorporated areas outside of UGAs. Given that approximately half off the Prairie Ridge 605 water system service area is in the City of Lacy UGA and half in unincorporated county area the county average is assumed. The median household income for Thurston County is approximately \$63,286 and ranks 5<sup>th</sup> out of counties in Washington State.


#### **2.1.2 ERU Analysis**

For the purpose of this report, one ERU is defined as the equivalent usage of a single-family residence occupied full time. Since all services are full time residential connections all connections represent a single ERU.

## **2.2 Water Production and Usage**

### **2.2.1 Meter Data**

Source and Service meters are read on a monthly basis. Service Meter records for the five-year period of September 2020 through August 2025 were used in developing a model of residential water demand for the community. During this period the number of full time residential and total connections has remained relatively unchanged, increasing from 294 ERU in September 2020 to 303 ERU in 2025.



**Figure 2-1: Monthly Average Consumption per ERU**

### 2.2.2 System Parameters: ADD, MDD, and PHD

Average daily demand (ADD) is 180 gpd/ERU. The Maximum Month Daily Demand (MMDD) was 370 gpd/ERU and occurred in August of 2021. Maximum Daily Demand (MDD) was calculated based on multiplying MMDD by a scaling factor of 1.65 and a safety factor of 1.1, yielding an MDD of 672 gpd/ERU.

The peak hourly demand (PHD) was estimated based on MDD using Equation 3-1 and Table 3-1 of the WSDM. PHD is calculated both for the existing 308 ERU (303 ERU plus 5 ERU of DSL) and for a buildup projection of 551 ERU.

$$\begin{aligned}
 PHD_{exist} &= \frac{MDD}{1440} ((C)(N) + F) + 18 = \frac{672}{1440} ((1.8)(308) + 125) + 18 = 335 \text{ gpm} \\
 PHD_{551 \text{ ERU}} &= \frac{MDD}{1440} ((C)(N) + F) + 18 = \frac{672}{1440} ((1.6)(551) + 225) + 18 = 534 \text{ gpm}
 \end{aligned}$$

**Table 2-1: Summary of Current Systems Design Parameters**

|                      |         |
|----------------------|---------|
| Existing Connections | 303 ERU |
| ADD/ERU              | 180 gpd |
| MDD/ERU              | 672 gpd |
| DSL                  | 4.7 ERU |
| DSL                  | 2.2 gpm |
| PHD                  | 335 gpm |
| PHD w/551 ERU        | 534 gpm |

### **2.2.3 Pressure Zones**

The consolidated system is comprised of two pressure zones. The upper pressure zone comprises the largest area of the system and serves 128 existing connections. The upper pressure zone maintains a hydraulic grade line of approximately 415 feet. Elevations within the upper pressure zone range from 240 to 300 feet; any services below an elevation of 240 feet require individual Pressure Reducing Valves (PRVs). The reservoirs and booster station and all direct to distribution wells pump into the upper pressure zone. The emergency intertie with the City of Lacey Water Department is also located in the upper pressure zone and is connected to the City of Lacey 400-foot hydraulic grade line pressure zone.

The lower pressure zone comprises most of the area south of Hawks Prairie Road, servicing 175 existing connections. The lower pressure zone maintains a hydraulic grade line of 370 feet and provides water service over an area with elevations ranging from 198 to 265 feet; any services below an elevation of 190 feet require individual Pressure Reducing Valves (PRVs). Based on existing zoning there is no further growth or subdivision expected in the lower pressure zone, therefore the only additional connections anticipated are from new Accessory Dwelling Units. The lower pressure zone is supplied from the upper zone via a Pressure Reducing Station and has no other internal source of supply.

The reservoirs and 4 of the 5 wells pump into the upper pressure zone; the emergency intertie to City of Lacey water system is also in the upper pressure zone. The lower pressure zone is supplied by a single well, and by two pressure reducing valves supplied by the upper pressure zone. Hydraulic analyses for both pressure zones at PHD and static conditions are included in Appendix 10.3.

Four of five existing sources, all storage, and the booster pump station are all located in the upper zone; the lower zone is supplied by S06, which is supplemented by the upper zone via two pressure reducing stations. Capacity analysis calculates that the upper pressure zone is limited to supply of 464 ERU, and the lower pressure zone to 320 ERU. The upper zone has significant capacity for growth but given 175 existing connections in the lower zone the overall Prairie Ridge system capacity is more limiting. Given existing platting it is unlikely the lower zone will experience significant future growth and is unlikely to exceed 200 connections within the next 20 years.

## 2.3 Distribution System Leakage

Distribution System Leakage (DSL) averaged 2.2 gpm over the past 5 years, exhibiting increasing rates as leaks developed and became significant enough for detection, followed by decline following detection and repair. The overall trend has been a slight decrease in average leak rate over this period. Overall, DSL has averaged 5.5 percent.




Figure 2-2: DSL Rate




Figure 2-3: Annual Average DSL Percent

## 2.4 Water Supply Characteristics

The Prairie Ridge water system is supplied by five groundwater wells, S01,S02,S04,S05,S06, with S01 and S02 being part of a well field designated as S03. Depth to open interval ranges from 120 to 280 feet below local ground level; compensated for surface elevation, four of the five wells have open intervals beginning at about 120 feet above mean sea level, with the open interval for S05 beginning at 50 feet below mean sea level. None of the wells have primary or secondary mcl exceedances. There is also an emergency intertie with the Lacey Water Department.

## 2.5 Water Supply Reliability Evaluation

The Prairie Ridge 605 water system is supplied by five wells with a total capacity of 340 gpm, none of which have any history of or significant concern for future contamination. Three wells pump direct to distribution, and two wells pump to the two reservoirs, which supply the distribution system via booster pumps. The booster pumps (combined capacity of 358 gpm) and four wells (with a combined source capacity of 260 gpm) are equipped with emergency backup power generators. Additionally, there is a nominal 1000 gpm emergency intertie with the Lacey Water Department. Given the high level of redundancy standby storage is not needed. Though no standby storage is necessary, the requested approval of 546 connections (551 ERU) effectively provides 100 gallons per connection standby storage.

### 2.5.1 Interties

There is a 6-inch intertie with a nominal capacity of 1000 gpm to the Lacey Water Department. The intertie is located in the upper pressure zone of the Prairie Ridge 605 water system (which maintains a nominal 415-ft hydraulic grade line), and the 400-ft hydraulic grade line zone of the Lacey Water Department. Both water systems are chlorinated and maintain the required minimum distribution system residual of 0.20 mg/L free chlorine. An intertie agreement defines operation and notifications between the water purveyors.

There are no other interties currently planned, however other interties which may be further explored in the future include Hawley Hills and Forest Park.

## 2.6 Future Population Projections and Land Use

There are three sources of likely growth in the Prairie Ridge 605 service area: Development of existing undeveloped parcels, redevelopment of underdeveloped parcels, and addition of accessory dwelling units. There are approximately 120 acres of undeveloped land within the service area, 70 acres of which are owned by Thurston County School District 3. An additional 230 acres consists of large lots which are currently developed as single-family homes and estates, but which may be rezoned and/or redeveloped in the future. Given the potential for all three modes of growth as described above, it is likely that

residential growth within the Prairie Ridge 605 service area will continue in line with the projected area average annual growth rate of 1.54% per Section 2.1.1.

In addition to residential growth, it is likely that Thurston County will begin development of a new school within the next 10 to 20 years. Projected student and staff population and extent of irrigated play fields is not currently known.

## **2.7 Future Water Demand**

Thurston PUD has a tiered rate structure in place which incentivizes conservation; given that this tiered rate has been in place for several years, it is unlikely that this will drive further reduction in water use and ADD per ERU is expected to remain relatively stable over time. DSL is also anticipated to remain relatively stable through a combination of main replacement and continued monitoring for and aggressively finding and fixing leaks. Should the new school be developed, there will be significant demand for both potable water and irrigation. As the timing, as well as the size and extent of the school and grounds is as yet unknown, a school is not included in the population and water use projections or in the water rights self-assessment or capacity planning. Currently however, Thurston PUD anticipates approximately 140 acre-feet per year to be available for a future school.

See water rights self-assessment in appendix 10.5 and capacity analysis of Section 3.3.

Table 2-2: Population and Water Use Projections

| Year | No. Connections | DSL ERU | ERU ADD (gpd) | System ADD (gpd) | ERU MDD (gpd) | System MDD (gpd) | PHD (gpm) | System Annual Use (ac-ft/yr) |
|------|-----------------|---------|---------------|------------------|---------------|------------------|-----------|------------------------------|
| 2025 | 303             | 4.9     | 180           | 57850            | 672           | 206926           | 335       | 64.80                        |
| 2026 | 308             | 5.0     | 180           | 58741            | 672           | 210113           | 339       | 65.80                        |
| 2027 | 312             | 5.1     | 180           | 59645            | 672           | 213348           | 343       | 66.81                        |
| 2028 | 317             | 5.2     | 180           | 60564            | 672           | 216634           | 347       | 67.84                        |
| 2029 | 322             | 5.2     | 180           | 61497            | 672           | 219970           | 351       | 68.89                        |
| 2030 | 327             | 5.3     | 180           | 62444            | 672           | 223358           | 356       | 69.95                        |
| 2031 | 332             | 5.4     | 180           | 63405            | 672           | 226797           | 360       | 71.02                        |
| 2032 | 337             | 5.5     | 180           | 64382            | 672           | 230290           | 364       | 72.12                        |
| 2033 | 342             | 5.6     | 180           | 65373            | 672           | 233837           | 369       | 73.23                        |
| 2034 | 348             | 5.7     | 180           | 66380            | 672           | 237438           | 373       | 74.36                        |
| 2035 | 353             | 5.7     | 180           | 67402            | 672           | 241094           | 378       | 75.50                        |
| 2036 | 358             | 5.8     | 180           | 68440            | 672           | 244807           | 382       | 76.66                        |
| 2037 | 364             | 5.9     | 180           | 69494            | 672           | 248577           | 387       | 77.84                        |
| 2038 | 370             | 6.0     | 180           | 70565            | 672           | 252405           | 392       | 79.04                        |
| 2039 | 375             | 6.1     | 180           | 71651            | 672           | 256292           | 397       | 80.26                        |
| 2040 | 381             | 6.2     | 180           | 72755            | 672           | 260239           | 402       | 81.50                        |
| 2041 | 387             | 6.3     | 180           | 73875            | 672           | 264247           | 407       | 82.75                        |
| 2042 | 393             | 6.4     | 180           | 75013            | 672           | 268316           | 412       | 84.03                        |
| 2043 | 399             | 6.5     | 180           | 76168            | 672           | 272448           | 417       | 85.32                        |
| 2044 | 405             | 6.6     | 180           | 77341            | 672           | 276644           | 422       | 86.63                        |
| 2045 | 411             | 6.7     | 180           | 78532            | 672           | 280904           | 427       | 87.97                        |
| 2046 | 418             | 6.8     | 180           | 79741            | 672           | 285230           | 433       | 89.32                        |
| 2047 | 424             | 6.9     | 180           | 80969            | 672           | 289623           | 438       | 90.70                        |

### 2.7.1 Other Systems

Interties are emergency only; therefore, no water use by other systems is considered.

## Chapter 3 System Inventory and Analysis

### 3.1 System Design Standards

All design and future construction shall be completed in accordance with the Washington State Department of Health Water System Design Manual (Design Manual) and Thurston PUD construction standards, which are found in Appendix A of the Umbrella Plan. The following is a brief summary of relevant standards set forth in the Design Manual:

|                     |          |     |
|---------------------|----------|-----|
| Water Demand        | Chapter  | 3   |
| PHD                 | Equation | 3-1 |
| Capacity Analysis   | Chapter  | 4   |
| Distribution System | Chapter  | 6   |
| Hydraulic Analysis  | Section  | 6.1 |

### 3.2 System Inventory and Asset Condition Assessment

See Thurston PUD's comprehensive asset management plan (found in the Part A WSP) for detailed inventory and capital replacement projections. A synopsis of the major system components is detailed below:

#### 3.2.1 Distribution System

The community's distribution system consists of an array of primarily 6" waterline, with smaller diameter pipe primarily serving cul-de-sacs. Waterlines are not looped but are equipped with blow-offs for flushing. A summary of pipe sizes and quantities in service are shown in Table 3-1.

Table 3-1: Pipe Inventory

| Nominal Pipe Size | Installed Length   |
|-------------------|--------------------|
| 2"                | 1,150 feet         |
| 2.5"              | 6,070 feet         |
| 3"                | 2,350 feet         |
| 4"                | 5,660 feet         |
| 6"                | 13,350 feet        |
| <b>Total</b>      | <b>28,580 feet</b> |

The community's sources and services are all metered. The service meters are read and billed monthly.

**Table 3-2: Valve, Blow-off, and Appurtenance Inventory**

| Component               | Number Installed |
|-------------------------|------------------|
| 2-in valve              | 3                |
| 2.5-in valve            | 11               |
| 3-in valve              | 4                |
| 4-in valve              | 7                |
| 6-in valve              | 28               |
| 2-in Blow-Off           | 13               |
| 2" PRV                  | 2                |
| Single Service Assembly | 45               |
| Double Service Assembly | 129              |

### 3.2.2 Sources

Prairie Ridge is supplied by 5 wells and an emergency intertie to the City of Lacey. Two wells (S01 and S02, forming well field S03) pump to the reservoir. The remaining three wells (S04, S05, and S06) pump directly to distribution. All wells are chlorinated to provide secondary disinfection, however no other treatment is necessary. Total non-emergency source capacity is 340 gpm. Well logs and available records are found in Appendix 10.2.

**Table 3-3: Summary of Sources**

|     | Well Name                 | Well Tag | Year Drilled | Well Depth | Static Water Level | Well Capacity (gpm) | Installed Well Pump (gpm) |
|-----|---------------------------|----------|--------------|------------|--------------------|---------------------|---------------------------|
| S01 | Prairie Ridge Well 1      | AKY156   | 1980         | 174'       | 134'               | 55                  | 55                        |
| S02 | Prairie Ridge Well 2      | AAE334   | 1995         | 183'       | 140'               | 82                  | 82                        |
| S03 | Prairie Ridge Well Field  | -        | -            | 183'       | 140'               | 137                 | 137                       |
| S04 | Hawk Acres Well 1         | AGN780   | 1969         | 174'       | 112'               | 55*                 | 55                        |
| S05 | Hawk Acres Well 2         | ALG212   | 2005         | 151'       | 112'               | 68*                 | 68                        |
| S06 | Tolmie Park Well 1        | AHG013   | 1979         | 280'       | 210'               | 80                  | 56                        |
| S07 | Intertie #1-City of Lacey |          | -            | -          | -                  | 1000                |                           |
|     | Total non-emergency       |          |              |            |                    | 340                 | 316                       |

\*S04 and S05 are highly productive and have been tested at 110 gpm with minimal drawdown.

**Table 3-4: Summary of Submersible Well Pumps**

| Source | Pumps to:           | Model                     | HP  | Set Depth | Drop Pipe | Date installed |
|--------|---------------------|---------------------------|-----|-----------|-----------|----------------|
| S01    | Reservoirs          | Franklin 60FH5S4-PE       | 5   | 147'      | 3" GIP    | 2025           |
| S02    | Reservoirs          | Franklin 75FA5S6-PE       | 5   | 169'      | 2.5" GIP  | 2021           |
| S03    | Reservoirs          | N/A (Well field, S01&S02) |     |           |           |                |
| S04    | Upper Pressure Zone | Franklin 60FA7S4-PE       | 7.5 | 136       | 2" GPP    | 2019           |
| S05    | Upper Pressure Zone | 10 HP 125 GPM             | 10  |           |           | 2005           |
| S06    | Lower Pressure Zone | Goulds 45GS75             | 7.5 | 262'      | 2" GIP    | 2025           |
| S07    | Upper Pressure Zone | (emergency intertie)      | -   |           |           | -              |

### 3.2.3 Water Rights and Capacity

The system has a total primary water right quantity of 380 gpm and 210 acre-feet per year. A comprehensive list of water rights and demand projections is found in the Water Right Self-Assessment form; the Water Rights Self-Assessment form and the water right certificates can be found in Appendix 10.4. The system is within their water rights based on annual usage, and based on water use projections, it is expected that annual water right is sufficient throughout buildout.

### 3.2.4 Storage

Storage is provided by two concrete reservoirs with a combined gross volume of 76,370 gallons. The reservoirs both have internal heights of 10-feet; tank volume below 6 inches and above 9 feet is dead storage (DS), with operational storage (OS) utilizing the interval from 8.5 to 9 feet. The remainder of the volume is available as working storage to provide Equalizing (ES) and Standby (SST) storage. The reservoir structures are in relatively good condition and have an expected lifespan of 75 years, with anticipated replacement in 2055 and 2075 respectively.

**Table 3-5: Summary of Submersible Well Pumps**

| Year Built | Size (ft)   | Gross Volume (gal) | DS (gal) | OS (gal) | ES (gal) | SST (gal) |
|------------|-------------|--------------------|----------|----------|----------|-----------|
| 1980       | 20'D x 10'H | 23,500             | 3,520    | 1,170    | 1,850    | 16,960    |
| 2000       | 30'D x 10'H | 52,870             | 7,930    | 2,630    | 4,150    | 38,150    |
| Total      |             | 76,370             | 11,460   | 3,800    | 6,000    | 55,110    |

### 3.2.5 Water Treatment

Secondary chlorination is provided via flow proportional injection of sodium hypochlorite at each well to achieve a minimum distribution system residual of 0.2 mg/L. Chlorination equipment consists of a small chemical tank, Stenner pump, and water meter.

### 3.2.6 Booster Pumps and Pressure Control

The system is pressurized by a 3 hp jockey pump and three 5 hp main pumps on variable speed drives, with an 80-gallon pressure tank for cycle control. Booster pump capacity is a combined 393 gpm at 50 psi.

**Table 3-6: Summary of Booster Pumps**

| Model                  | HP | Operating pressure (psi) | Output (gpm) | Date installed |
|------------------------|----|--------------------------|--------------|----------------|
| Flint & Walling C22233 | 3  | 50                       | 60           | 2013           |
| Flint & Walling C22253 | 5  | 50                       | 111          | 2013           |
| Flint & Walling C22253 | 5  | 50                       | 111          | 2013           |
| Flint & Walling C22253 | 5  | 50                       | 111          | 2026           |

### 3.2.7 Buildings

Three existing buildings currently serve the water system and will continue to be in use. These buildings house pumps, electrical, and chlorination equipment. The Hawk Acres building has a planned addition to house chlorination equipment; the Tolmie Park building will be remodeled due to poor condition. See Table 3-7 for building summary.

**Table 3-7: Summary of Buildings**

| Site             | Building Size | Year Constructed | Notes                  |
|------------------|---------------|------------------|------------------------|
| Booster Station  | 14' x 14'     | 1980             | Electrical new in 2013 |
| Hawk Acres Wells | 4' x 6'       | 2007             | Electrical new in 2017 |
| Tolmie Park Well | 8' x 20'      | 1991             | Poor condition         |

### 3.2.8 Backup Power Generators

The Hawk Acres well site is equipped with a propane backup generator, automatic transfer switch, and 500-gallon propane tank that were installed in 2017. The backup power system maintains power to S04, S05, and chlorination during power outages. A new propane backup generator along with an automatic transfer switch and two 1,000-gallon propane tanks are being installed at the booster station site to run the booster pumps, S01 and S02, and chlorination and controls. There are no plans to install backup power at S06, as more than sufficient capacity is available during power outages to meet maximum day demand without S06.

## 3.3 Capacity Analysis

The system has the capacity to supply 530 ERU; see Worksheet 4-1 on following page.

**Table 3-8: Limiting Factor Capacity Summary**

| Component            | ERU Capacity |
|----------------------|--------------|
| Source(s)            | 564          |
| Treatment            | 564          |
| Storage              | 530          |
| Pumping              | 601          |
| Water Rights         | 1,029        |
| Other (Distribution) | 687          |

## Worksheet 4-1 --ERU Capacity Summary

6/1/2021

### Specific Single Family Residential Connection Criteria (measured or estimated demands.)

Average Day Demand (ADD) 180 gpd/ERU  
 Maximum Day Demand (MDD) 672 gpd/ERU

| Water System Connections Correlated to ERUs                               |                                       |   |      |
|---|---------------------------------------|---|------|
| Service Classification  | Total MDD for the classification, gpd | Total # Connections in the classification | ERUs |
| <b>Residential</b>  |                                       |   |      |
| Single-family   | 203,616                               | 303                                       | 303  |
| Multifamily   |                                       |   |      |
| <b>Nonresidential</b>   |                                       |   |      |
| Industrial  |                                       |   |      |
| Commercial  |                                       |   |      |
| Governmental  |                                       |   |      |
| Agricultural  |                                       |   |      |
| Recreational  |                                       |   |      |
| Other (specify)   |                                       |   |      |
| DSL   | 3,130                                 |   | 4.7  |
| <b>Other (identify)</b>   |                                       |   |      |
| <b>Total existing ERUS (Residential + Nonresidential + DSL + Other) =</b> |                                       |   | 308  |

| Service Capacity as ERUs and Gallons Per Day  |                                 |                                 |                    |
|---|---------------------------------|---------------------------------|--------------------|
| Water System Component (Facility)             | ERU Capacity for Each Component | GPD Capacity for Each Component | Notes              |
| Source(s)                                     | 564                             | 379,200                         |                    |
| Treatment                                     | 564                             | 379,200                         |                    |
| Equalizing Storage                            | 530                             | 8,120                           |                    |
| Standby Storage                               | 530                             | 52,980                          |                    |
| Pumping                                       | 601                             | 823,680                         |                    |
| Water Rights (Qa)                             | 1,029                           | 187,476                         | average annualized |
| Water Rights (Qi)                             | 1,082                           | 727,200                         |                    |
| Other (Distribution)                          | 687                             | 915,840                         |                    |
| <b>Water System Service Capacity (ERUs) =</b> |                                 |                                 | 530                |

(Based on the limiting water system component shown above.)

**Note:** For the purposes of capacity analysis and water system plans, this form needs to be accompanied by the calculations that were used to come up with the ERU capacity figures.

- Capacity determinations are only for existing facilities that are operational for the water system
- Not shown above are distribution system limitations (Section 4.5.4) on ERUs because these are location-specific within the distribution system. These limits are not expected to limit the ERU capacity of the entire water system.

### Capacity Analysis Calculations

|                                  |             |
|----------------------------------|-------------|
| Average Day Demand (ADD)         | 180 gpd/ERU |
| Maximum Day Demand (MDD)         | 672 gpd/ERU |
| Current Peak Hourly Demand (PHD) | 335.0 gpm   |

**Table 3-1**

| Number of ERUs (N) | C   | F   |
|--------------------|-----|-----|
| 15-50              | 3.0 | 0   |
| 51-100             | 2.5 | 25  |
| 101-250            | 2.0 | 75  |
| 251-500            | 1.8 | 125 |
| >500               | 1.6 | 225 |

#### **Source Capacity**

|  |         |
|--|---------|
| Source capacity pumping to reservoirs (WF 3 /Sources 1 and 2)          | 137 gpm |
| Source capacity pumping direct to distribution (Sources 4, 5, and 6)   | 179 gpm |
| Total Non-Emergency System Source Capacity                             | 316 gpm |
| With Equalizing Storage (Must supply system MDD in 20 hours, Equ. 4-3) | 564 ERU |

|   |         |
|---|---------|
| <b>Treatment</b> (treatment capacity + non treated sources)       | 316 gpm |
| '-Proportional chlorine injection, same capacity as well capacity | 564 ERU |

|   |                |
|---|----------------|
| <b>Total Live Storage:</b>                | 61100 gallons  |
| Available Equalizing Storage (ES) volume: | 8,120 gallons  |
| ES Capacity per Equ. 4-5                  | 530 ERU        |
| Available Standby Storage (SB)            | 52,980 gallons |
| SB Capacity 100 gallons per ERU           | 530 ERU        |

|   |         |
|---|---------|
| <b>Booster Pump Capacity</b> (booster pumps + direct to distribution sources) | 572 gpm |
| Distribution Capacity (Must supply system PHD per Equ. 3-1)                   | 601 ERU |

|  |         |
|--|---------|
| <b>Distribution Capacity</b> (limited by 8fps or 30 psi in distribution) | 636 gpm |
| Distribution Capacity (Must supply system PHD per Equ. 3-1)              | 687 ERU |

|  |              |
|--|--------------|
| <b>Annual water right</b>                      | 210 ac-ft/yr |
| Average Daily limit:                           | 187476 gpd   |
| Average Daily limit less average DSL:          | 184346 gpd   |
| Annual water right capacity (adjusted for DSL) | 1029 ERU     |

|  |            |
|--|------------|
| <b>Instantaneous water right</b>                             | 505 gpm    |
| Max daily limit  | 727200 gpd |
| Instantaneous water right capacity (with equalizing storage) | 1082 ERU   |

|  |         |
|--|---------|
| Limiting number of ERUs                      | 530 ERU |
| Existing number of calculated ERUs           | 308 ERU |
| Proposed increase in number of approved ERUs | 222 ERU |

|  |            |
|--|------------|
| Existing number of total connections                               | 303        |
| Proposed increase in number of approved connections (assumes SFRs) | 222        |
| <b>Requested number of approved connections:</b>                   | <b>525</b> |
| Resulting PHD  | 518.4 gpm  |

### Capacity Analysis Calculations Upper Zone

#### Source Capacity (upper zone)

|  |         |
|--|---------|
| Source capacity pumping to reservoirs (WF 3 /Sources 1 and 2)          | 137 gpm |
| Source capacity pumping direct to distribution (Sources 4, 5)          | 123 gpm |
| Total Non-Emergency System Source Capacity                             | 260 gpm |
| With Equalizing Storage (Must supply system MDD in 20 hours, Equ. 4-3) | 464 ERU |

|   |         |
|---|---------|
| <b>Treatment</b> (treatment capacity + non treated sources)       | 260 gpm |
| '-Proportional chlorine injection, same capacity as well capacity | 464 ERU |

#### Total Live Storage:

|   |                |
|---|----------------|
| Operational Storage (OS)                              | 28,900 gallons |
| Dead Storage (DS)                                     | 13,453 gallons |
| Fire Flow Storage (FFS) (Nested with Standby Storage) | 45000 gallons  |

#### Total available storage for ES and SB:

|   |                |
|---|----------------|
| Available Equalizing Storage (ES) volume: | 13,070 gallons |
| ES Capacity per Equ. 4-5                  | 480 ERU        |
| Available Standby Storage (SB)            | 48,030 gallons |
| SB Capacity 100 gallons per ERU           | 480 ERU        |

#### Booster Pump Capacity (booster pumps + direct to distribution sources)

|   |         |
|---|---------|
| Distribution Capacity (Must supply system PHD per Equ. 3-1) | 526 ERU |
|---|---------|

#### Distribution Capacity (limited by 8fps or 30 psi in distribution)

|   |         |
|---|---------|
| Distribution Capacity (Must supply system PHD per Equ. 3-1) | 687 ERU |
|---|---------|

#### Annual water right

|  |                |
|--|----------------|
| Average Daily limit:                           | 179.5 ac-ft/yr |
| Average Daily limit less average DSL:          | 160247 gpd     |
| Annual water right capacity (adjusted for DSL) | 160247 gpd     |
|  | 895 ERU        |

#### Instantaneous water right

|  |            |
|--|------------|
| Max daily limit  | 612000 gpd |
| Instantaneous water right capacity (with equalizing storage) | 911 ERU    |

#### Limiting number of ERUs

|                                    |         |
|------------------------------------|---------|
| Existing number of calculated ERUs | 128 ERU |
|------------------------------------|---------|

Resulting PHD

469.7 gpm

### Capacity Analysis Calculations Lower Zone

#### Source Capacity

|  |         |
|--|---------|
| Source capacity (lower zone)               | 56 gpm  |
| PRV capacity                               | 420 gpm |
| Total Non-Emergency System Source Capacity | 476 gpm |
| Capacity to meet PHD                       | 473 ERU |

**Storage Capacity:** provided by upper zone, same limitation as for entire water system

|  |         |
|--|---------|
| <b>Distribution Capacity</b> (limited by 8fps or 30 psi in distribution) | 362 gpm |
| Distribution Capacity (Must supply system PHD per Equ. 3-1)              | 320 ERU |

**Water right:** same as system as a whole

|                                    |           |
|------------------------------------|-----------|
| Limiting number of ERUs            | 320 ERU   |
| Existing number of calculated ERUs | 175 ERU   |
| Resulting PHD                      | 361.8 gpm |

### 3.3.1 Water Rights Self-Assessment

See completed Water Rights Self-Assessment documents in Appendix 10.5 for existing status and 20-year forecast.

### 3.3.2 Source of Supply Analysis

The water system is served by a five groundwater sources with combined capacity exceeding MDD at buildout. Additionally, there is an emergency intertie to the City of Lacey water system, as well as a reservoir providing equalizing and standby storage. There is no history of seasonal well decline or known source vulnerabilities.

## 3.4 Distribution System Analysis

### 3.4.1 Model Description

Distribution System hydraulics were modeled using EPAnet 2.2. The system consists of two pressure zones, with the upper zone at an average hydraulic gradient of 415 ft, and the lower zone at an average hydraulic gradient of 370 ft. The upper zone is supplied from the booster station and the Hawk Acres wells (S04 and S05). The lower zone is supplied by the Tolmie Park well (S06) and two pressure reducing stations fed by the upper zone. A surface roughness of 150 was used for PVC pipes, with service connections modeled as nodes with variable demand scaled according to the scenario. Pumps were modeled based on the given pump's curve, with a PRV valve used to set output pressure, and a water supply via a reservoir. Reservoir surface elevation was set to the pumping water elevation for wells, or the applicable storage reservoir level for booster pumps. Pressure reducing stations were modeled as PRV valves with set point pressures analogous to design setpoints. Demand was assigned by multiplying the unit demand at the node by a scenario scaling factor.

### 3.4.2 Scenarios

The system does not provide fire flow; therefore, the following scenarios were analyzed:

- Static Conditions (at pump shutoff pressure)
- Peak hourly demand flow rates (buildout condition of 530 connections)
- Average MDD flow at buildout with S04 and S05 offline
- Average MDD flow at buildout with S06 offline
- Average MDD flow at buildout with two booster pumps offline
- Average MDD flow at buildout with all pumps and wells offline and supply via the intertie to City of Lacey
- Distribution system limiting factor (max flow while maintaining pressure above 30 psi and velocity below 8 fps).

### 3.4.3 Model Results

Model results show that the distribution system is relatively efficient and exhibits minor friction losses under most conditions, with pressure differences largely driven by elevation. The distribution system is able to support up to 687 ERU distributed as infill and ADU's. The distribution system is also capable of supplying MDD flow rates at above 30 psi under emergency conditions (multiple pumps/wells offline).

At buildout PHD conditions of 520 gpm pressure at services ranges from 37.6 psi to 63.2 psi. The distribution system limiting factor was found to be pressure; the system is able to supply up to 636 gpm while maintaining pressure above 30 psi at all points in the distribution system.

All upper pressure zone services below 242-ft elevation and lower zone services below 190-ft elevation require individual pressure reducing valves in order to maintain pressures below 80 psi. There are no existing services at elevations requiring individual pressure reducing valves.

### **3.5 Summary of System Deficiencies**

Following pump replacements and rebuilding of the Hawk Acres and Tolmie Park pump houses with the consolidation project, all known deficiencies have been addressed and the water system's infrastructure is in good working order. The system has no significant hydraulic capacity limitations, and DSL is well below the 10% target. Modeling suggests that the system will be able to provide adequate flow and pressure through any likely level of community build out and occupancy. The system is not currently capable of providing fire flow, but this is not considered a deficiency because it is not required due to the system being grandfathered in under prior regulations. Should fire flow be required for future development, it may be provided, though some system upgrades will be required.

## Chapter 4 Water Use Efficiency Program

In 2003, the Washington State Legislature passed Engrossed Second Substitute House Bill 1338, known as the Municipal Water Law, to address increasing demand on the state's water resources. The law established that all municipal water suppliers must use water more efficiently in exchange for water right certainty and flexibility to help them meet future demand. The Legislature directed the Department of Health to oversee and enforce a WUE program to help support the collective goal of ensuring a safe and reliable drinking water supply. The WUE program seeks to support this goal in the following ways:

- Contribute to long-term water supply reliability and public health protection,
- Promote good stewardship of the state's water resources, and
- Ensure efficient operation and management of water systems.

This program became effective on January 22, 2007 and established certain responsibilities that water suppliers must fulfill. Fundamental elements include the following:

- Water use efficiency program,
- Distribution leakage standard,
- Goal setting and performance reporting, and
- Metering requirements

This chapter summarizes Webster Hill's compliance with conservation planning requirements including the actions taken to promote water use efficiency, and the conservation program that the system will implement. The applicable WUE program requirements and guidelines are contained in *Water Use Efficiency Guidebook*, Revised May 2025(DOH 331-375).

### 4.1 Source and Service Metering

#### 4.1.1 Source Meters

All sources are metered. Any additional sources developed in the future will be metered when installed.

#### 4.1.2 Service Meters

The system is fully metered. Meters are read and billed monthly. The system billing software provides month by month total usage reports which are used for calculating distribution system leakage. All new services will be metered upon activation.

### 4.2 Distribution System Leakage

If a system's distribution system leakage exceeds 10 percent, the conservation program must also provide an implementation program that includes leak detection and repair, and other measures to reduce water loss. Leak loss for the past five-year period has averaged 5.9%, and for the past three-year period has averaged 4.9%. It should be noted that for four months of the year 2021 and 10 months of the year 2022 the source meter for the Tolmie Park well was not functional, resulting in missing DSL data for the then Tolmie Park water system. To account for this lack of record the available source production data for the

previous and following 2 years was averaged to yield an estimated monthly source production volume for the missing months. Consumption (service) metering is available for the past 7 years, and the DSL calculated by using the actual consumption data and estimated production data for the months missing production data is in line with the system's long-term trend. Given the general trend of DSL at Tolmie Park has been downward over time and given that Tolmie Park comprises only about 20% of the total connections in the consolidated Prairie Ridge water system, this is considered an accurate approach. See Figure 2-2: DSL Rate for historical trend.

The Hawk acres water system has experienced a recent source meter accuracy issue, resulting in apparent negative DSL over the past year. Both Hawk Acres source meters are past typical lifespan and are being replaced January 2026. Meter inaccuracy appears to have begun developing in May or June of 2024; this has no impact on consumption demand; however, DSL calculations have been adjusted by applying the prior 3-year average DSL rate of 31,750 gallons per month (based on years 2021 through 2023) for the most recent period starting May 2024.

## **4.3 Water Use Efficiency Program**

### **4.3.1 Current Program**

The Thurston PUD Board of Commissioners recognizes that water is a valuable commodity, and the wise and efficient use of water is a goal that is in the best interests of its constituents. Staff have training and equipment to respond to leak reports from customers generally within a few hours of the report. Significant discrepancies between service meter and source meter records are investigated.

### **4.3.2 Goals**

State regulation (WAC 246-290-830) requires the governing body of the municipal water system to develop the water use efficiency goals through a public process. The current WUE goal was considered in a public meeting held on October 19, 2020. The current goal for years 2021 through 2030 is to reduce and/or maintain the annual average demand per connection, for all Group A systems, to no more than 250 gallons per day. The Prairie Ridge water system is currently meeting this goal.

### **4.3.3 Measures**

As part of a water system plan, DOH regulations also require the implementation of a specified number of water use efficiency measures. WAC 246-290-810 identifies the minimum number of water use efficiency measures that must be evaluated based on system size. Thurston PUD has less than 9,999 connections and therefore must evaluate or implement six supplementary water use efficiency measures in addition to the mandatory measures. Please see Part A WSP, chapter 3.4 for Water Use Efficiency Measures.

In addition to water efficiency measures identified in the Part A WSP, Thurston PUD currently offers customers the following efficiency related devices and incentives:

- Shower Timers -first come first serve basis
- Irrigation Timers -first come first serve basis
- Soil Moisture Meters -first come first serve basis

- High Efficiency toilet rebate (\$50.00)

#### **4.3.4 Reclaimed Water**

Systems serving more than 1,000 connections are required to evaluate reclaimed water opportunities. Most of the Prairie Ridge system is comprised of properties that have private septic systems and therefore would not be able to implement a sewer treatment plant for reclaimed water use. With fewer than 1,000 connections, the system is not required to further evaluate reclaimed water opportunities.

#### **4.3.5 Consumer Education Program**

Thurston PUD sends out seasonal water conservation tips to customers at least bi-annually within our monthly newsletter. Conservation is also included in our annual consumer confidence reports. Newsletters can be found online at <http://www.thurstonpud.org/pud-news-newsletters.htm>

#### **4.3.6 Annual Reports**

The annual report provided to DOH by July 1 must include:

- Total system production and system wide consumption
- Distribution system leakage in percentage and volume
- Goal description, schedule, and progress toward meeting goals

Thurston PUD submits the annual WUE report on DOH's SENTRY database system, <https://fortress.wa.gov/doh/eh/portal/odw/si/Disclaimer.aspx?Page=FindWaterSystem.aspx>, before July 1 every year and adds a copy of the report to the website at [http://www.thurstonpud.org/water-systems-ccr-2017\\_copy\(1\).htm](http://www.thurstonpud.org/water-systems-ccr-2017_copy(1).htm). Additionally, the District reports this information to each customer on the annual Consumer Confidence Reports (CCR), example included in the Part A Water System Plan, Appendix J. The CCR provides each individual water system the current goal, total water produced and what the average household used for that water system.

#### **4.3.7 Water Rates**


Please see Water System Plan Part A, Section 6-6 and 6-7 for discussion and evaluation of current and future rates. Please see Thurston PUD website for current rates and fees <http://thurstonpud.org/our-rates.htm>.

### **4.4 Demand Forecast**

See Sections 2.6 and 2.7 for population and demand forecasting.

### **4.5 Water Use Efficiency Savings**

Thurston PUD has a significant successful history of improving water use efficiency at water systems owned and operated by the PUD. Over the past 7 years, Thurston PUD has consistently reduced leak loss, from approximately 10% in 2018 to under 6% in 2024. The 3-year running average DSL for the consolidated system is under 5%. See WSP Part A section 3.8 for additional history of WUE Program success at Thurston PUD water systems.



**Figure 4-1: Annual Average DSL Percent**

## 4.6 DSL Exemption for Water Systems under 500 Connections

The Prairie Ridge water system currently serves less than 500 connections; however the system maintains an average DSL below 10% and does not request the DSL exemption at this time.

## **Chapter 5 Source Water Protection**

### **5.1 Wellhead Protection**

The wellhead protection program has been developed in conjunction with the WSP. The following susceptibility assessment, protection area, and contamination source inventory will provide the necessary documentation to make educated management and land use decisions to prevent aquifer contamination.

#### **5.1.1 Susceptibility Assessment**

Ground Water Contamination Susceptibility Assessment forms for each source for the Prairie Ridge Water System are included in Appendix 10.6. The results of the assessment are summarized in this Chapter.

#### **5.1.2 Wellhead Protection Area**

A map showing the 100-foot protected radii and the 6-month, 1-year, 5-year, and 10-year ground water travel radii is given below. The well protection radii are calculated using the formula found in the susceptibility assessment as provided by the WSDOH.

#### **5.1.3 Contamination Source Inventory**

The following are potential sources of contamination within the 10-year travel time radii:

1. Residential Septic Systems
2. Minor Residential Chemical Applications (Pesticides, herbicides, etc.)
3. Stormwater detention ponds
4. Active and inactive land disturbance permits
5. Target Warehouse facility
6. Gas station
7. Private and County Roadways

#### **5.1.4 Notification of Findings**

The following agencies will be provided with a letter (see Appendix 10.6 for a copy of the notification letter) requesting information about any potential sources of contamination within the Wellhead Protection Radii:

Thurston County Health Department  
Thurston County Community Planning and Economic Development  
Emergency Services (911)  
Washington State Department of Ecology

A letter to all the homeowners with lots within the 10-year radii will also be sent a notification letter. See Appendix 10.6 for copies of the notification letters.



**Figure 5-1: Wellhead Protection Areas**

### **5.1.5 Contingency Planning**

The well is provided with continuous disinfection, therefore biological contamination is unlikely. In the event of contamination, the well would be taken offline. Thurston PUD has an emergency intertie with the City of Lacey, and the ability to provide residents with bottled water or to resupply the reservoir by tanker.

## **5.2 Water Quality Analysis**

### **5.2.1 Bacteriological Testing**

The system tests the distribution system for coliform bacteria each month per the coliform monitoring plan, Located in Appendix 10.7. There have been no exceedances in the past 10 years. All other parameters are tested based on the water quality monitoring schedule, located in Appendix 10.7. The water system has historically exceeded the secondary MCL for manganese and is in the process of installing treatment. There are no other known water quality exceedances.

## Chapter 6 Operations and Maintenance

### 6.1 Water System Management, Personnel, and Certifications

See Thurston PUD WSP Part A, Sections 5.1 and 5.2.

### 6.2 Operations and Preventative Maintenance

The routine operation and preventative maintenance schedule for the system infrastructure is outlined in the WSP Part A in Chapter 5, Table 5-2, and further detailed in Appendix M. O & M procedures are fully detailed in Appendix N of the WSP Part A.

#### 6.2.1 Normal Operating Conditions and Settings

Table 6-1 outlines the normal setpoints for the well pumps, reservoirs levels, and booster pumps.

Table 6-1: Normal Operating Conditions

| Component                               | Pumps To          | On Condition                      | Set Point                          | Off Condition                            |
|---|-------------------|-----------------------------------|------------------------------------|--|
| Well 1 & 2                              | Reservoir 1       | 8.5 ft                            | -                                  | 9.0 ft                                   |
| Booster Pumps                           | Upper Zone        | 52 psi                            | 56 psi                             | 30 Hz                                    |
| Well 4 & 5                              | Upper Zone        | 65 psi                            | 69 psi                             | 30 Hz                                    |
| Well 6                                  | Lower Zone        | 55 psi                            | 59 psi                             | 30 Hz                                    |
| Chlorination                            | After all sources | Flow detected                     | 0.6 mg/L<br>Flow rate proportional | No flow                                  |
| City of Lacey Intertie (Emergency Only) | Upper Zone        | open PUD & Lacey isolation valves | 400-ft                             | PUD & Lacey isolation valves both closed |

### 6.3 Comprehensive Water Quality Monitoring

The system is sampled in accordance with its Water Quality Monitoring Schedule (WQMS), located in Appendix 10.7. If any water quality testing exceeds the standards set forth in WAC 246-290-310, the DOH will be notified immediately.

#### 6.3.1 Coliform Monitoring Plan and Map

The coliform monitoring plan can be found in Appendix 10.7. The system takes one routine samples per month from distribution. If there are any failures, repeat distribution samples and a source sample are taken per this plan. See the Coliform Monitoring Plan for details. Response Plans can be found in the Emergency Response Plan in the WSP Part A, Appendix P.

#### 6.3.2 Lead and Copper Monitoring

The Lead and Copper Monitoring plan can be found in Appendix 10.7.

### **6.3.3 Water Treatment Monitoring**

Chlorine residual is measured downstream of the reservoir 5 days per week and reported to WSDOH on a monthly basis.

### **6.3.4 Disinfection Byproduct Monitoring**

The Disinfection Byproduct Monitoring Plan can be found in Appendix 10.7.

## **6.4 Emergency Response Program**

The Emergency Response Plan is found in the WSP Part A, Appendix P.

## **6.5 Cross Connection Control**

The cross-connection control policy and program are located in the WSP Part A, Appendix R. A list of backflow devices can be found in this WSP Part B, Appendix 10.7.

## **6.6 Sanitary Survey Findings**

The latest Sanitary Survey were performed in 2025 on the three individual systems. Finding for each system are:

- Prairie Ridge 605 - No significant deficiencies or findings were observed.
- Hawk Acres 607 – One significant deficiency of electrical conduits needing to be sealed was completed by the due date.
- Tolmie Park 239 – One significant deficiency of a portable toilet in the 100 ft SCA which was removed as soon as possible.

## **6.7 Summary of O&M Deficiencies**

Overall, the system is well maintained with repairs and upgrades routinely made. All significant system deficiencies identified during the most recent Sanitary Survey have been addressed. Other O&M items to be addressed include:

### **6.7.1 Clean and Repair Pumphouse**

The pumphouse should be cleaned and undergo minor repair, including ventilation improvement.

### **6.7.2 Continue to Find and Fix Leaks**

Thurston PUD has found and fixed all significant leaks and reduced leak loss considerably, however as the distribution system ages it will continue to develop leaks. Leak loss should continue to be monitored, with leaks found and fixed in a timely manner.

## **6.8 Record Keeping, Reporting, and Customer Complaint Program**

See WSP Part A, Section 5.9

## **6.9 Customer Complaint Response Procedures**

See WSP Part A, Section 5.10

## **Chapter 7 Distribution Facilities Design and Construction Standards**

Thurston PUD requests a distribution main extension submittal exemption for the Prairie Ridge 605 water system as allowed under WAC (246-290-125 (2)). The distribution design and construction standards are outlined in the Thurston PUD WSP Part A, Appendix A. Maps of the distribution system is available in Section 10.10 of this WSP Part B.

## Chapter 8 Capital Improvement Program

### 8.1 Prioritization Criteria

Improvements are prioritized according to the following criteria listed from highest to lowest in importance:

1. Public Health Risks
2. Adequate Supply
3. WSDOH Operation and Design Standards
4. Achieving Conservation Goals
5. Regularly Scheduled Improvements
6. Aesthetic and Optional Improvements

### 8.2 Prioritized List of Improvements

Improvements Planned for 2026 as part of the consolidation are:

1. Distribution upgrades (service meters in Hawk acres and Tolmie Park, PRV stations, new/replaced 6-in mains intertying Hawk Acres to Prairie Ridge and Tolmie Park)
2. Rebuild Tolmie Park well house (S06) and install of upsized well pump
3. Installation of 3<sup>rd</sup> main booster pump
4. Installation of upgraded pump controls and telemetry system wide, Installation of secondary chlorination at S04, S05, S06
5. Install Backup Generator at reservoir site to power S01, S02, and Booster Station

Future improvements include:

6. Rebuild Prairie Ridge booster station
7. 2035 mainline replacement
8. New well (S08)

### 8.3 Assessment of Improvements

#### 8.3.1 Distribution Upgrades

Installation of approximately 1,800 linear feet of 6-in distribution main in an unopened ROW area of Stillwell Rd from Legacy Lane to Hepburn St, intertying the existing Prairie Ridge and Hawk Acres distribution systems. Installation of approximately 1400 linear feet of 4-in distribution main in Eagle Dr, intertying the existing Hawk Acres and Tolmie Park service areas. Two small PRV vaults, to be located at the corners of Stillwell Rd and Eagle Dr, and Eagle Dr and Hawks Prairie Rd for the regulation of pressure to the lower pressure zone. Replacement of meters in the existing Hawk Acres and Tolmie Park service areas.

### **8.3.2 Rebuild Tolmie Park well house (S06) and install of upsized well pump**

An upsized well pump is required at S06 (Tolmie Park) to enable pumping direct to distribution. This requires replacement of the submersible pump, as well as upgraded power supply, electrical, and controls. The existing building is not fit for purpose and must be replaced prior to electrical upgrades.

### **8.3.3 Installation of 3rd main booster pump**

An additional 5 hp booster pump at the Prairie Ridge booster station is needed to provide redundancy to the consolidated system.

### **8.3.4 Installation of upgraded pump controls and telemetry system wide, Installation of secondary chlorination**

Consolidation requires upgrades to pump controls and telemetry for interoperability between the dispersed well/pump sites. The existing Prairie Ridge system has secondary chlorination, requiring secondary chlorination systems be installed at S04, S05, and S06 in order to ensure a minimum residual of 0.2 mg/L free chlorine is maintained throughout the entire distribution system.

### **8.3.5 Install Backup Generator**

A backup generator to power the booster station during a utility power outage is necessary to ensure continuity of water service. There is an existing backup generator which is able to power S04 and S05; with backup power to the booster station and S04 and S05 the system has sufficient emergency capacity with redundancy so backup power is not necessary or planned for S06. The lower pressure zone will be supplied from the upper zone via the PRVs during utility power outage.

### **8.3.6 Rebuild Prairie Ridge Booster Station Building**

The Prairie Ridge booster station building was built in 1980 and in declining condition. Reconstruction of walls and roof is planned for 2030.

### **8.3.7 2035 mainline replacement**

Approximately 5,000 feet of mainline and 42 service laterals (76 total services, consisting of 8 singles and 34 doubles) were installed in 1970; replacement is planned for these areas in approximately 2035. Existing mains consist of approximately 1200 feet of 6-inch AC, 650 feet of 3-inch PVC, and 3,200 feet of 2.5-inch PVC.

### **8.3.8 New Well (S08)**

Ground water permit G2-29250P approves the drilling of an additional well in S34, T34N, R01W, with a production capacity of up to 125 gpm. The permit anticipates an 8-inch diameter well drilled to approximately 175-ft deep and tied into the same conveyance system as S01 and S02. The need for S08 is based on development by the school district and is tentatively planned for 2035.

## 8.4 Improvement Program Summary and Schedule

Table 8-1 provides an overview of the likely schedule for capital improvements projects. See Umbrella Plan Appendix U for details of the financial program.

Table 8-1: Improvement Schedule

| Project  | Estimated Cost | Estimated Year to be Completed | Funding Source             |
|--|----------------|--------------------------------|----------------------------|
| Distribution upgrades  | \$615,000      | 2026                           | DWSRF Loan, Capital Budget |
| Rebuild Tolmie Park well house (S06) and install of upsized well pump                                      | \$90,000       | 2026                           | DWSRF Loan                 |
| 3 <sup>rd</sup> main booster pump  | \$25,000       | 2026                           | DWSRF Loan                 |
| Upgraded pump controls and telemetry system wide, Installation of secondary chlorination at S04, S05, S06. | \$100,000      | 2026                           | DWSRF Loan                 |
| Backup Generator at reservoir site   | \$120,000      | 2026                           | DWSRF Loan                 |
| Rebuild Prairie Ridge Booster Station Building   | \$130,000      | 2030                           | Capital Budget             |
| 2035 Mainline Replacement  | \$1,600,000    | 2035                           | Capital Budget             |
| New Well (S08)   | \$500,000      | 2035                           | Capital Budget             |

## **Chapter 9 Financial Program**

See WSP Part A, Section 6. Thurston PUD's current Asset Management Program incorporates planning for all 273 Thurston PUD systems can be downloaded from the Thurston PUD website or made available upon request.

## **Chapter 10 Appendices and Supporting Documents**

- 10.1      Hydraulic Analysis**
- 10.2      Well Logs, Pump Curves, and Equipment**
- 10.3      Meter Data**
- 10.4      WFI and Operating Permit**
- 10.5      Water Rights**
- 10.6      Wellhead Contamination Susceptibility Assessments**
- 10.7      Water Quality Monitoring Programs, Cross Connection Control**
- 10.8      Consistency Statements, WSP Adoption, and Correspondence**
- 10.9      Easements, Covenants, Legal Instruments**
- 10.10     Maps and Drawings**