WATER WELL REPORT Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller	CURRENT Notice of Intent No. WE05989		
E.C.O.L.O.G.Y	Unique Ecology Well ID Tag No. ALH951		
Construction/Decommission ("x" in circle)  Construction	Water Right Permit No. EXEMPT WELL		
Decommission ORIGINAL INSTALLATION Notice	Property Owner Name TODD A. HANSEN/LUFCO LLC		
2 of Intent Number			
253119	Well Street Address 8525 SE AYER STREET		
PROPOSED USE: Domestic Industrial Municipal  DeWater Irrigation Test Well Other	City OLYMPIA County THURSTON		
TVDE OF WORK. Owner's number of well (if more than one)	Location NW 1/4-1/4 NE 1/4 Sec 18 Twn17N R1W ewm check		
TITE OF WORK: Owner's multiplet of well (it male than one)	WWM 7 one		
☐ Deepened ☐ Cable ☐ Rotary ☐ Jetted	(Lat/Long (s, t, r Lat Deg Lat Min/Sec Lat Min/Sec Lat Min/Sec Lang Mi		
DIVIENSIONS. Diameter of wen 12 menes, direct 37 menes	Long Deg Long Min/Sec		
Depth of completed well 97 ft.  CONSTRUCTION DETAILS	Tax Parcel No. 11718120200		
	141744001110.		
Casing Installed:         ✓ Welded Properties         12         Diam. from +1.5         ft. to 54         ft.           Installed:         ✓ Liner installed 8         Diam. from from ft.         Threaded ft. to ft.	CONSTRUCTION OR DECOMMISSION PROCEDURE		
Perforations: Yes No	Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of		
Type of perforator used	information. (USE ADDITIONAL SHEETS IF NECESSARY.)		
SIZE of perfs in. by in. and no. of perfs from ft. to ft	MATERIAL	FROM TO	
ALLOVANOURIE MODICO	SILT BOUND SAND, LARGE GRAVEL	0 16	
Manufacturer's Name ALLOY MACHINE WORKS	GRAY SAND	16 29	
Diam. 8 Slot size .030 from 53 ft. to 78 ft.	BROWN SILTY SAND, SOME GRAVEL	29 46	
Diam. Slot size from it. to it	BROWN SILT BOUND FINE SAND	46 49	
40 0 07	BROWN SILTY MEDIUM SAND (HEAVING) WATER	80	
	GRAY SILTY FINE SAND	80 97	
Surface Seal: Yes No To what depth? 21 ft.  Material used in seal BENTONITE CHIPS	OTO TO SELL THINE OF WAS	00 01	
Did any strata contain unusable water?			
Type of water? Depth of strata			
Method of sealing strata off			
PUMP: Manufacturer's Name			
WATER LEVELS: Land-surface elevation above mean sea levelft.  Static levelft. below top of wellft.			
Artesian pressure lbs per square inch Date			
Artesian water is controlled by			
(cap, valve, etc.)			
WELL TESTS: Drawdown is amount water level is lowered below static level  Was a pump test made? ✓ Yes □ No If yes, by whom? ADI			
Yield: 75 gal./min. with 20 ft. drawdown after 1 hrs.			
Yield: 150 gal/min. with 32 ft drawdown after hrs. Yield: 250 gal/min. with 46 ft. drawdown after hrs.			
Recovery data (time taken as zero when pump turned off) (water level measured from well		A LANGE WAS DOWN	
top to water level)		JEIVED	
Time Water Level Time Water Level Time Water Level			
		8 2 0 2007	
Date of test	187		
Bailer test 60 gal./min. with 8 ft. drawdown after 6 hrs.		hington State	
Airtestgal./min. with stem set atft. forhrs.	Depart	nent of Ecology	
Artesian flow g.p.m. Date			
Temperature of water Was a chemical analysis made?	Chart Date 12/10/06	d Data 1/16/07	
		d Date <u>1/16/07</u>	
WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all			
Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.  □ Driller □ Engineer □ Trainee Name (Print) MARK H. NELSON			
Driller Engineer Trainee Name (Print) MARK H. NELSON  Driller/Engineer/Trainee Signature  Mark Wellson			
Driller or trainee License No 1992			
TRAINING			
Driller's Licensed No	Contractor's Registration No. ARCADDI098K1	Date 1/30/07	
Driller's Signature	_J		