



Longhorn Country Est 687 2025 Water Quality Report

Thurston PUD is pleased to present your 2025 Annual Water Quality Report.

This report contains important information about the quality of water and services we deliver to you every day. We encourage you to read and learn how we monitor your drinking water to ensure it meets all primary state and federal regulations.

On page 3, you'll find the most recent water quality results through the monitoring period ending December 31, 2025.

If you would like to receive more information about current water quality issues, make comments, or ask questions, please contact our Planning and Compliance Department at PUDPlanning@thurstonpud.org or call our office at (360) 357-8783, Option 3 between 8 a.m. and 4 p.m. Monday through Friday.

Conservation *Saving Water Can Be Simple*

Water is a precious, limited resource. When we each do our part in conservation, using only as much water as we need, we help ensure enough water remains available to meet the needs of wildlife and our growing community.

Want to learn more about saving water indoors and out?

- Check out our website at <https://www.thurstonpud.org/water-systems.htm>, you will find water-saving tips and practices to utilize at home.
- Our monthly newsletters also feature conservation articles year-round, read the current and historical newsletters on our website at <https://www.thurstonpud.org/newsletters.htm>.

Get Involved

Commission meetings are held the second and fourth Tuesday of every month.

The meetings start at 5:00 p.m. and are open to the public.

Check out our website at www.thurstonpud.org

How To Contact Us...

Office Address:

1230 Ruddell Road SE
Lacey, WA 98503

Phone Number (s):

(360) 357-8783 or 1 (866) 357-8783

Email:

PUDCustomerService@thurstonpud.org

Website:

www.thurstonpud.org

WATER USE EFFICIENCY ANNUAL REPORT

Thurston PUD is required to send you a Water Use Efficiency Report on an annual basis. In compliance with the state Municipal Water Law, Thurston PUD approved and implemented a 10-year conservation goal in October 2020 for your water system. The goal is as follows:

REDUCE AND/OR MAINTAIN THE ANNUAL AVERAGE DEMAND PER CONNECTION, FOR ALL GROUP A SYSTEMS, TO NO MORE THAN 250 GALLONS PER DAY.

The Longhorn water system is fully metered and the total water produced for 2025 was 1,655,922 gallons. The system had less than one gallon per minute leak loss for the year. In 2025 the average household used 123 gallons per day meeting the PUD's current conservation goal.

A copy of the report filed with the state is available on our website. To receive a copy by mail, please call our office at (360) 357-8783.

LEAD AND DRINKING WATER *What you need to know*

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Thurston PUD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

To help reduce potential exposure to lead in drinking or cooking water, flush water through the tap if the water has not been used for 6 hours or more, until the water is noticeably colder before using. You can use the flushed water for watering plants, washing dishes, or general cleaning. Only use water from the cold-water tap for drinking, cooking, and especially for making baby formula. Hot water is likely to contain higher levels of lead. If you are concerned about lead in your water, you may have your water tested. Information on lead in drinking water is available from the EPA's Safe Drinking Water Hotline at 1-800-426-4791 or online at <http://www.epa.gov/safewater/lead>.

CROSS-CONNECTION CONTROL *Protecting the Water You Drink from Backflow*

Thurston PUD, in accordance with WAC 246-290-490, administers a cross-connection control program that helps protect your drinking water by preventing contaminants from entering your water system through inspections, public education, and requiring physical devices called backflow prevention assemblies. Backflow prevention assemblies allow water to travel one-way into a customer-owned piping system, such as an irrigation or fire suppression system, and does not allow water to flow back into the community water supply if a back-siphonage or backpressure condition exists.

Thurston PUD staff members currently track and manage over 1,300 backflow assemblies as part of the cross-connection control program. Each assembly is required to be tested annually to ensure they are functioning properly to help safeguard the water that you, your family, and your neighbors utilize every day. Requiring a backflow assembly on an underground irrigation system that is connected to the drinking water supply is one way we help to prevent contaminants from entering your community water system.

A garden hose can create a cross-connection! The end of a garden hose can be connected to or come into contact with many potential contaminants. Never submerge hoses in buckets, spas, animal watering troughs or any other receiving vessel. A hose bibb vacuum breaker (see illustration) is an inexpensive, easy to install device designed to help prevent backflow through your garden hoses. They are available at most hardware stores and only cost approximately \$7 each.

Two ways to help keep your water safe from cross-connections:

1. Fill out a new cross-connection survey form (www.thurstonpud.org) every time you add anything to your system.
2. Send in your required annual test results for any backflow device you have installed on your irrigation system.

If you are not sure if your underground irrigation system has a backflow assembly installed, or if you have any other questions about Thurston PUD's cross-connection control program and requirements, please contact the Planning & Compliance Team at backflow@thurstonpud.org or (360) 357-8783, Option 3.



ANNUAL WATER QUALITY REPORT: Longhorn Country Estates 687 - ID 30190J

Your water comes from a single 70 foot deep groundwater well and includes a 2,100 gallons of storage. The system is approved for 34 connection.

Source	Susceptibility Rating	Treatment
S01 ABS214	High	None

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2025 calendar year. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk.

We test for Primary and Secondary Contaminants both regulated and unregulated, as required by the EPA and the State Department of Health. The regulated and unregulated analysis (contaminants) tests are commonly referred to as Inorganic Chemical (IOC), Volatile Organic Chemical (VOC) and Synthetic Organic Chemical (SOC) tests.

Required Testing (last testing date):

Monthly Bacteriological	Volatile Organic Contaminants – 2021	Herbicide and/or Pesticide – 2019
Annual Nitrate	Radionuclide – 2024	PFAS – 2025 None Detected
Inorganic Contaminants – 2022	Lead & Copper – 2023	

PRIMARY CONTAMINANTS

<i>Microbiological</i>	<i>MCLG</i>	<i>MCL</i>	<i>Your Water</i>	<i>Compliant(Y/N)</i>	<i>Typical Sources</i>
Total Coliform Bacteria	N/A	TT	0	Y	Naturally present in the environment.
<i>Inorganic Contaminants</i>	<i>MCLG</i>	<i>MCL</i>	<i>Your Water</i>	<i>Compliant(Y/N)</i>	<i>Typical Sources</i>
Nitrate (ppm)	10	10	3.54	Y	Runoff from fertilizer use
<i>State Regulated</i>	<i>SRL</i>	<i>SMCL</i>	<i>Your Water</i>	<i>Compliant(Y/N)</i>	<i>Typical Sources</i>
Sodium (ppm)*	5	N/A	7.2	Y	Geology, natural weathering.
<i>Lead & Copper Taken at Customer Taps</i>	<i>AL</i>	<i>No. of Homes Sampled</i>	<i>90th Percentile Value</i>	<i>No. of Homes Exceeding AL</i>	<i>Typical Sources</i>
Lead (ppb)	15	5	8.8	0	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	1.3	5	0.89	1	
<i>Radioactive Contaminants</i>	<i>MCLG</i>	<i>MCL</i>	<i>Your Water</i>	<i>Compliant(Y/N)</i>	<i>Typical Sources</i>
Radium 228 (pCi/l)	0	5	0.25	Y	Erosion of natural deposits

*While there is no published MCL for sodium, waters with sodium levels in excess of 20 mg/l may be a concern to individuals suffering from hypertension or monitoring their sodium intake.

Terms and Abbreviations Used:

ppm - parts per million **ppb** - parts per billion **N/A** - Not Applicable
ND - None Detected **TT** - Treatment Technique **pCi/l** - picocuries per liter

Contaminant: A substance that impairs the quality of potable water and may create a hazard to public health.

MCLG (Maximum Contaminant Level Goal): the level of a contaminant in drinking water below which there is no know or expected risk to health. MCLGs allow for a margin of safety.

MCL (Maximum Contaminant Level): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL (Action Level): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

SRL (State Reporting Level): The minimum reportable detection of an analyte as established by Washington State Department of Health. If the test result is less than the SRL, the contaminant is considered not detected.

SMCL (Secondary Maximum Contaminant Level): These standards are developed as guidelines to protect the aesthetic qualities of drinking water and are not health based.

SOME CONTAMINANTS ARE REASONABLY EXPECTED TO BE FOUND IN DRINKING WATER

To ensure that tap water is safe to drink, the Department of Health and EPA prescribe regulations that limit the number of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and the Washington Department of Agriculture regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Drinking water, including bottled drinking water, may be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 1-800-426-4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and Herbicides*, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally occurring or be the result of oil and gas production and mining activities.

Source Protection Information

The Washington State Department of Health Office of Drinking Water has compiled Source Water Assessment Program (SWAP) data for all community water systems in Washington. A source water assessment includes:

- A delineation (definition) of the source water protection area.
- An inventory of potential sources of contamination, and
- A susceptibility determination (how susceptible the source is to contamination).

SWAP data for your system is available online at <https://fortress.wa.gov/doh/swap/>

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health



Vulnerable Populations

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline www.epa.gov/safewaterhotline